





To Set Desired DBA Sound Output Level:

 High Level Output (factory settings)
Set Switch 1 To On Position



 Standard Level Output
Set Switch 1 To Off Position



Jumper Settings To Select 12 or 24 VDC



 12 VDC



 24VDC

To Set Desired Alarm tone:

 Horn  March Time Horn

 Bell  Code 3 Horn

 Siren  Code 3 Tone

 Hi/Lo  Slow Whoop

Note: The code-3 Horn and Tone alert sounds are reserved for emergency evacuation signaling. They should not be used for any other purpose!